

MassDEP NOI File Number

CERO NOI@MassMail.state.ma.us <CERO NOI@MassMail.state.ma.us>

Tue 7/2/2024 1:50 PM

To:jlinden@uptonma.gov <jlinden@uptonma.gov>;thomas.rebula@mass.gov <thomas.rebula@mass.gov>;mburne@bscgroup.com <mburne@bscgroup.com>

Cc:cero_noi@state.ma.us <cero_noi@state.ma.us>;Mary Overholt <moverholt@uptonma.gov>;Conservation Commission <concomm@uptonma.gov>;cero_noi@state.ma.us <cero_noi@state.ma.us>

COMMONWEALTH OF MASSACHUSETTS

EXECUTIVE OFFICE OF ENERGY & ENVIRONMENTAL AFFAIRS

DEPARTMENT OF ENVIRONMENTAL PROTECTION

CENTRAL REGIONAL OFFICE

8 NEW BOND STREET, WORCESTER, MA 01606 508-792-7650

Date: 07/02/2024

Municipality UPTON

RE: **NOTIFICATION OF WETLANDS PROTECTION ACT FILE NUMBER**

The Department of Environmental Protection has received a Notice of Intent filed in accordance with the Wetlands Protection Act (M.G.L. c. 131, §40):

Applicant	TOWN OF UPTON	Owner
Address	1 MAIN STREET, UPTON MA 01568	Address
Locus	0 WARREN STREET , UPTON MA 01568	

This project has been assigned the following file #: **CE 311-0827**

ISSUANCE OF A FILE NUMBER INDICATES ONLY COMPLETENESS OF SUBMITTAL, NOT APPROVAL OF APPLICATION

Although a file # is being issued, please note the following:

MassDEP recommend that the applicant and Commission verify the presumed perennial nature of the stream located on the subject parcel as based on review of the most recent USGS map of the site it appears to be mapped as intermittent and would therefore not have RA resource associated with it. RA associated with Center Brook appears to fall off locus of all proposed work. The applicant should provide test pit data in the location of the proposed bioretention area to demonstrate adequate separation from ground water consistent with the design and siting criteria for bioretention areas found in Volume 2 Chapter 2 of the MA Stormwater Handbook

Regards,

for MassDEP,

(508)-767-2721

Thomas.Rebula@Mass.gov